



THE KERALA STATE HOMOEOPATHIC CO. OPERATIVE PHARMACY LTD.

(SPONSORED BY GOVERNMENT OF KERALA)

Pathirappally.P.O, ALAPPUZHA, KERALA -688521

QUOTATION NOTICE

Quotation No: HOMCO/QT-20/2026-27

25.07.2026

‘HOMCO’ invites competitive sealed Quotation for supply, installation, testing, and commissioning of bore well submersible pump”.

Sl.No	Specifications	Quantity
1.	Minimum discharge: 5,000 litres/hour Head: Suitable for the existing bore well depth Pump diameter: 100 mm Motor rating: 3 HP, 3 Phase, 415 V (compatible with the existing starter panel and power cable) • Head range: 20–130 metres • Delivery size: 40 mm • Recommended makes: Kirloskar, Crompton, CRI, Lubi, Texmo, or equivalent approved brands	1

- Suppliers shall submit the detailed technical data sheet of the proposed submersible pump along with their quotation for technical evaluation.
- The successful supplier shall dismantle and remove the existing borewell submersible pump prior to the installation of the new pump.
- The existing HDPE delivery pipe, submersible pump cable, and steel safety wire may be reused for the installation of the new pump.
- Any additional materials required for the successful installation and commissioning of the new pump shall be clearly indicated in the quotation.

Last Date of receipt of Quotation is 3 pm, on 31.07.2026

Quotation Opening: 31.07.2026 3.30 pm

NO COST FOR QUOTATION DOCUMENTS AND NO EMD IS REQUIRED

Details of Quotation is available from the Office working hrs from 25.07.2026 2 pm.

Designation and address of officer to whom the quotation is to be addressed: **The Managing Director, HOMCO, Pathirappally, Alappuzha, Pin:688521, Ph:0477 225 8012, 225 8665**

The Cover should be superscribed as “Quotation for supply, installation, testing, and commissioning of bore well submersible pump”

The Managing Director reserves the right to accept or reject any or all quotations without assigning any reason whatsoever.

Alappuzha

25.07.2026

(Sd/-)

Managing Director